

5. Tapering bits are a trip hazard - remove, restrict or delineate

4. Restrict access so this is not mistaken as path of travel

2. 1200 - 1500 wide

1. Increase incline to min. 1:20 to define as 'walkway'

7. Primary access points to be provided with tactiles and handrails (north & south)

6. This section is the biggest trip hazard - recommend to remove or restrict.

3. Change in material along walkway (doesn't need to be orange)

