

VS-C-10.1

CONTRACTOR DOCUMENT REVIEW

NO EXCEPTION TAKEN  
REJECTED

Aurecon Australia Pty Ltd  
ACN 005 139 873

Date: 225219.001

Project No: 18-11-11

Date received: 18 NOV 2011

This review is only for general compliance with the design concept of the project and does not constitute an order or authority for a price variation to the contract.

CONTRACTOR DOCUMENT REVIEW

NO EXCEPTION TAKEN  
REJECTED

Aurecon Australia Pty Ltd  
ACN 005 139 873

Date: 225219.001

Project No: 18-11-11

Date received: 19 NOV 2011

This review is only for general compliance with the design concept of the project and does not constitute an order or authority for a price variation to the contract.

What is the orientation of this dimension? Is it 125D x 75W or 75D x 125W. Please confirm. Thank you.

HSS TUBE

75(?) x 150(?)

125 x 75 RHS

for 1500 SPAN OK

125 H

75V

TAPERED W SHAPE CATWALK & SCREEN SUPPORT (SPACING ON CENTER?)

FOR SPANNING UP TO 1500 mm

FOR SPANNING UP TO 3000 mm

→ 250 x 150 RHS

250 H



150V

some conditions →

200 x 100 RHS

200 H



100V

X-BRACING REQUIRED.

12-φ rods.

